



Rivera Backflow & Plumbing

Backflow testing · Repair · Installation · TX
RMP #40711

Backflow Prevention Assembly Test and Maintenance Report

R-001042

SERVICE PROVIDER

Rivera Backflow & Plumbing
Austin, TX
(555) 010-0142

CUSTOMER

Eastside Taqueria
Attn: Jane Roe
2401 E 6th St, Austin, TX 78702

DATE

Oct 7, 2026

TIME ON SITE

08:40 - 10:15

TECHNICIAN

John Doe

PUBLIC WATER SUPPLIER

NAME OF PWS

City Water Utility

PWS ID #

TX0000000

PWS MAILING ADDRESS

100 Main St, Austin, TX 78701

PWS CONTACT PERSON

Cross-connection program

STATEMENT

The backflow prevention assembly detailed below has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters.

ASSEMBLY

TYPE OF BPA

RPBA

MANUFACTURER & MODEL (MAIN)

Watts 909

SERIAL # (MAIN)

7731-A

SIZE (MAIN)

2"

BPA LOCATION

Mechanical room, north wall

BPA SERVES

Domestic

REASON FOR TEST

Existing

INSTALLED PER MANUFACTURER
RECOMMENDATIONS AND/OR LOCAL
CODES

Yes

INSTALLED ON A NON-POTABLE
(AUXILIARY) SUPPLY

No

INITIAL TEST

1ST CHECK HELD AT

6.4 psid

RELIEF VALVE OPENED AT

3.2 psid

1ST CHECK

Closed tight

2ND CHECK

Closed tight

INITIAL TEST

Passed

DIFFERENTIAL PRESSURE GAUGE

GAUGE USED ON

Potable

MAKE / MODEL

Watts TK-DP

SERIAL #

22-5517

DATE TESTED FOR ACCURACY

Jun 9, 2026

LICENSED TESTER

BPAT LICENSE #	LICENSE EXPIRATION DATE
BP0012345	Aug 3, 2027

CERTIFICATION

The above is certified to be true at the time of testing.

NOTE

Test records must be kept for at least three years [30 TAC §290.46(b)]. Use only manufacturer's replacement parts. A signed and dated original must be submitted to the public water supplier for recordkeeping purposes.

LICENSED TESTER  John Doe · 10:22 AM BPAT BP0012345		CUSTOMER  Jane Roe · 10:24 AM
--	--	--