



Keystone Fire Protection

Extinguishers · Suppression · Emergency lighting · AZ ROC
#331875

Fire Extinguisher Inspection Report

R-001042

SERVICE PROVIDER

Keystone Fire Protection
Phoenix, AZ
(555) 010-0142

CUSTOMER

Desert Sky Dental
Attn: Pat Example
4110 N 7th St, Phoenix, AZ 85014

DATE

Oct 7, 2026

TIME ON SITE

08:40 – 10:15

TECHNICIAN

Erin Roe

INSPECTION TYPE

Annual maintenance

EXTINGUISHERS

LOCATION	TYPE	SIZE (LB)	SERIAL #	MFG. YEAR	SERVICE	NEXT HYDRO	RESULT
Kitchen exit	Class K (wet chemical)	6	K19-22817	2019	Annual	2029	Pass
Front entry	ABC dry chemical	10	AB14-55102	2014	Recharge	2026	Action needed
Storage room	ABC dry chemical	5	AB21-09931	2021	Annual	2033	Pass

GENERAL

#	ITEM	FINDING	RESULT
01	Mounting & visibility		Pass
02	Signage	Storage room sign missing.	Action needed
03	Accessible, unobstructed		Pass
04	Gauges in operable range		Pass
05	Hoses & nozzles		Pass
06	Tags updated		Pass
07	Pins & tamper seals		Pass

DUE NEXT YEAR (6-YEAR / HYDRO)

Front entry ABC 10 lb: 12-year hydrostatic test due 2026.


TECHNICIAN LICENSE / PERMIT #

FL 12345-P

FIRM CERTIFICATE OF REGISTRATION #

FEX-00123

PHOTOS



Front entry unit, gauge low 08:52

NOTES & RECOMMENDATIONS

Front entry extinguisher due for 6-year maintenance; recharged and tagged.

CERTIFICATION

The extinguishers listed above were inspected and maintained in accordance with NFPA 10 and the fire code adopted where they are located.

TECHNICIAN



Erin Roe · 10:22 AM
NAFED Certified · Fire Marshal Permit #FE-2209



CUSTOMER



Pat Example · 10:24 AM