



SERVICE PROVIDER

Summit Plumbing Co.

Denver, CO

(555) 010-0142

CUSTOMER

Richard Roe

Attn: Richard Roe

1840 S Pearl St, Denver, CO 80210

DATE

Oct 7, 2026

TIME ON SITE

08:40 - 10:15

TECHNICIAN

Sam Roe

REPORTED PROBLEM

Kitchen sink draining slowly, gurgling in dishwasher.

AREA

☒ Kitchen ☐ Bathroom ☐ Water heater ☒ Main line ☐ Laundry ☐ Exterior

INSPECTION

#	ITEM	FINDING	RESULT
01	Static water pressure	62 psi	Pass
02	Water heater & T&P valve		Pass
03	Shut-off valves	Kitchen hot shut-off seized.	Action needed
04	Drain flow	Main line partially blocked.	Action needed
05	Visible leaks		Pass

WATER PRESSURE

62 psi


WORK PERFORMED

Cleared main line with 3/8" cable to 60 ft, roots at 48 ft. Flow restored, tested with 10 min run.

PARTS USED


PART	QTY
Quarter-turn angle stop 1/2" x 3/8"	1

PHOTOS



Roots removed at 48 ft

08:52



Seized shut-off

09:21

NOTES & RECOMMENDATIONS

Recommend camera inspection and root treatment within 6 months.

TECHNICIAN

[Signature]

Sam Roe · 10:22 AM
Journeyman Plumber



CUSTOMER

[Signature]

Richard Roe · 10:24 AM