



SERVICE PROVIDER

Lakeshore Heating & Cooling

Mississauga, ON

(555) 010-0142

CUSTOMER

Lakeview Dental Clinic

Attn: Jane Smith

1250 Lakeshore Rd E, Mississauga, ON L5E 1E9

DATE

Oct 7, 2026

TIME ON SITE

08:40 – 10:15

TECHNICIAN

Sam Doe

EQUIPMENT

UNIT

RTU-2

DETAILS

details: Carrier 48TC · S/N 4519G20118

DESCRIPTION OF THE SERVICE

Annual leak test, coil cleaning, topped up charge after repairing a leaking Schrader core.

REFRIGERANT TYPE

R-410A

REFRIGERANT USED (ADDED)

0.9 kg

REFRIGERANT OBTAINED FOR THIS JOB

1 kg

OBTAINED FROM (SUPPLIER)

Local refrigeration wholesaler

REFRIGERANT RECAPTURED (ESTIMATE)

0 kg

LEAK TEST

LEAK TEST RESULT

No leak

TECHNICIAN ODP CERTIFICATE #

ODP 0123456


CERTIFICATE EXPIRY

Feb 19, 2028

BEFORE REFILLING

Refrigerant may only be added when a leak-test notice showing no leak, dated within the last 6 months, is attached to the equipment. Attach a printed copy of this record's leak test to the equipment.

PHOTOS



Schrader core replaced 08:52

TECHNICIAN

[Handwritten signature]

Sam Doe · 10:22 AM
ODP0123456



CUSTOMER

[Handwritten signature]

Jane Smith · 10:24 AM